

Tijuana River (TJR) NERR Meteorological Metadata
January – December 2016
Latest Update: August 28, 2017

I. Data Set & Research Descriptors

1) Principal investigator(s) & contact persons

Jeff Crooks, Research Coordinator	301 Caspian Way Imperial Beach, CA 91932 Phone: (619) 575-3613 Fax: (619) 575-6913 E-mail: jcrooks@tijuanaestuary.org
-----------------------------------	---

Justin McCullough, Research Associate	301 Caspian Way Imperial Beach, CA 91932 Phone: (619) 575-3613 x321 E-mail: jmccullough@trnerr.org
---------------------------------------	---

2) Entry verification

Data are uploaded from the CR1000 data logger to a Personal Computer (IBM compatible). Files are exported from or LoggerNet in a comma-delimited format and uploaded to the CDMO where they undergo automated primary QAQC and become part of the CDMO's online provisional database. During primary QAQC, data are flagged if they are missing or out of sensor range. The edited file is then returned to the Reserve where it is opened in Microsoft Excel and processed using the CDMO's NERRQAQC Excel macro. The macro inserts station codes, creates metadata worksheets for flagged data and summary statistics, and graphs the data for review. It allows the user to apply QAQC flags and codes to the data, append files, and export the resulting data file to the CDMO for tertiary QAQC and assimilation into the CDMO's authoritative online database. For more information on QAQC flags and QAQC codes, see Sections 11 and 12. Justin McCullough is responsible for all data management.

3) Research objectives (Campbell Weather Station):

The principal objective is to record long-term and episodic meteorological data for the Tijuana River Estuary in order to observe any environmental changes or trends over time. Data are also used as corollary information in ongoing biological, hydrological and geographical studies being conducted at the reserve.

4) Research Methods

A model CR1000 Campbell Scientific datalogger samples meteorological sensors every 5 seconds. At 15 minute intervals, averages, totals, or instantaneous readings are taken, depending upon sensor type, and written to a storage table on the CR1000. Data are reported in Pacific Standard Time (PST) for the year.

Monthly, sensors on the weather station are inspected for damage or debris. If any is found, it is repaired and/or cleaned. Sensors are removed and sent back to Campbell Scientific for calibration at minimum of every one to two years

depending on the sensor. There were no other analyses done on the meteorological data at present.

Campbell Scientific data telemetry equipment was installed at the Tidal Linkage station on 06/12/2006 and transmits data to the NOAA GOES satellite, NESDIS ID #3B01468A. The transmissions are scheduled hourly and contain four (4) data sets reflecting fifteen minute data sampling intervals. Upon receipt by the CDMO, the data undergoes the same automated primary QAQC process detailed in Section 2 above. The "real-time" telemetry data become part of the provisional dataset until undergoing secondary and tertiary QAQC and assimilation in the CDMO's authoritative online database. Provisional and authoritative data are available at <http://cdmo.baruch.sc.edu>.

Data collection information:

- The 15 minute Data are collected in the following formats for the CR1000:
- Averages from 5-second data:
 - Air Temperature (°C), Relative Humidity (%), Barometric Pressure (mb), Wind Speed (m/s), Wind Direction (degrees), and Battery Voltage (volts)
- Maximum, Minimum, and their times from 5-second data:
 - Maximum and Minimum Air Temperature (°C) (these data are available from the Reserve)
 - Maximum Wind Speed (m/s)
- Wind Direction Standard Deviation (degrees) from 5-second data
- Totals:
 - Precipitation (mm), PAR (millimoles/m²), and Cumulative Precipitation (mm)

Recommended calibration frequency for the MET station sensors:

- Temperature/Humidity- yearly recalibration
- Rain Gauge- yearly recalibration
- Wind Speed/Direction- every 2 years (depending on the sensor)
- Barometric Pressure- every 2 years recalibration
- Photosynthetically Active Radiation (PAR) - Apogee Quantum Sensor - every 2 years
- CR1000-every 5 years (required beginning 2014, one year initial grace period)

5) Site location and character:

The Tijuana River NERR is located on the Southern Pacific Coast, next to the California border with Mexico at a latitude of 32 deg. 34 min. N and Longitude of 117 deg. 07 min. W. The area surrounding the 2,531 acre reserve is heavily developed by residential housing as is the watershed which drains into the estuary. Approximately 2/3 of the watershed is in Mexico and is subject to periodic raw sewage outflows. The North Eastern section is bordered by a military helicopter training base. Vegetation in the area is dominated by common pickleweed (*Salicornia pacifica*) and Pacific cordgrass (*Spartina foliosa*).

Description of the specific sampling station:

The weather station is located approximately 30m west of the TR NERR Visitor Center at a Latitude of 32deg 34min 28.2sec N and a Longitude of 117deg 07min 37.2sec W. The station is about 800m northeast of the water quality sampling station at Oneonta Slough. The vegetation surrounding the weather station is mainly upland scrub species.

The anemometer, wind direction and PAR sensors are located at the top of a 3.5 meter aluminum tower. The temperature and humidity sensors are located midway up (~1.75m) and on the west side of the tower. The barometric pressure sensor is mounted in the CR1000 enclosure at a height of 1.5m. The Tipping Bucket rain gauge (relocated in 2014) is attached to the fence 2.4 meters to the south-southwest of the main tower. It is 2m above the ground to limit interference from the security fence surrounding the weather station. The sensors were wired to the CR1000 following the protocol in the CDMO Manual.

SWMP Station Timeline:

Station Code	Station Name	SWMP Status	Location	Active Dates	Reason Decommissioned	Notes
TJRTLNET	Tidal Linkage	P	32° 34' 28.20 N, 117° 7' 37.20 W	01/01/2001-	NA	NA

6) Data collection Period

Data was collected for all parameters at the station from 01/01/2016 00:00 and continued through 12/31/2016 23:45.

File Start Date and Time	File End Date and Time
12/14/2015 10:45	01/15/2016 08:45
01/15/2016 09:00	02/16/2016 14:00
02/16/2016 14:15	03/21/2016 10:30
03/21/2016 10:45	04/14/2016 13:45
04/14/2016 14:00	05/05/2016 11:45
05/05/2016 12:00	06/15/2016 15:00
06/15/2016 15:15	07/18/2016 12:45
07/18/2016 13:00	08/15/2016 11:15
08/15/2016 11:30	09/16/2016 12:00
09/16/2016 12:00	10/14/2016 14:00
10/14/2016 14:15	11/16/2016 13:45
11/16/2016 14:00	12/19/2016 12:45
12/19/2016 12:00	01/17/2017 12:45

7) Distribution

NOAA retains the right to analyze, synthesize and publish summaries of the NERRS System-wide Monitoring Program data. The NERRS retains the right to be fully credited for having collected and process the data. Following academic courtesy standards, the NERR site where the data were collected should be contacted and fully acknowledged in any subsequent publications in which any part of the data are used. The data set enclosed within this package/transmission is only as good as the quality assurance and quality control procedures outlined by the enclosed metadata reporting statement. The user bears all responsibility for its subsequent use/misuse in any further analyses or comparisons. The Federal

government does not assume liability to the Recipient or third persons, nor will the Federal government reimburse or indemnify the Recipient for its liability due to any losses resulting in any way from the use of this data.

Requested citation format:

NOAA National Estuarine Research Reserve System (NERRS). System-wide Monitoring Program. Data accessed from the NOAA NERRS Centralized Data Management Office website: <http://www.nerrsdata.org/>; accessed 12 October 2016.

NERR meteorological data and metadata can be obtained from the Research Coordinator at the individual NERR site (please see Principal Investigators and Contact Persons), from the Data Manager at the Centralized Data Management Office (please see personnel directory under the general information link on the CDMO home page) and online at the CDMO home page www.nerrsdata.org. Data are available in comma delimited format.

8) Associated researchers and projects

The meteorological station is part of the NERRS System Wide Monitoring Program (SWMP) that also includes data collection for water quality, using YSI data loggers for in situ measurements (temperature, salinity, dissolved oxygen, turbidity, pH and water depth) and grab samples to analyze nutrient contents (orthophosphate, chlorophyll, ammonia, nitrate/nitrite) in the laboratory.

II. Physical Structure Descriptors

9) Sensor specifications

Parameter: Photosynthetically Active Radiation (PAR)

Apogee Quantum Sensor

Units: mmol/m² (total flux)

Sensor type: High stability silicon photovoltaic detector (blue enhanced)

Model#: SQ-110

Serial#: 18025

Light spectrum waveband: 410 to 655 nm

Temperature dependence: .06± .06% per °C

Stability: ± 2% change over 1 yr

Operating Temperature: -40°C to 70°C; Humidity: 0 to 100%

Sensitivity: 0.2 mV per μmol m⁻² s⁻¹

Multiplier: 0.025

Date installed: April 20, 2015

Date of last calibration: March 18, 2015

Dates in service: 04/20/2015 - current as of 12/31/2016

Parameter: Wind speed

Units: meter per second (m/s)

Sensor type: 18 cm diameter 4-blade helicoids propeller molded of polypropylene

Model#: R.M. Young 05103 Wind Monitor

Serial#: 57955

Range: 0-100 m/s (224 mph)

Accuracy: ± 1%

Date of last factory calibration: September 5, 2014

Dates in service: 09/30/2014 - 11/18/2016

Parameter: Wind direction

Units: degrees

Sensor type: balanced vane, 38 cm turning radius

Model#: R.M. Young 05103 Wind Monitor
Serial#: 57955
Range: 360° mechanical, 355° electrical (5° open)
Accuracy: $\pm 3^\circ$
Date of last factory calibration: September 5, 2014
Dates in service: 09/30/2014 - 11/18/2016

Parameter: Wind speed
Units: meter per second (m/s)
Sensor type: 18 cm diameter 4-blade helicoids propeller molded of polypropylene
Model#: R.M. Young 05106 Wind Monitor - Marine
Serial#: WM 150921
Range: 0-100 m/s (224 mph)
Accuracy: $\pm 1\%$
Date of last factory calibration: September 29, 2016
Dates in service: 11/18/2016 - current as of 12/31/2016

Parameter: Wind direction
Units: degrees
Sensor type: balanced vane, 38 cm turning radius
Model#: R.M. Young 05106 Wind Monitor - Marine
Serial#: WM 150921
Range: 360° mechanical, 355° electrical (5° open)
Accuracy: $\pm 3^\circ$
Date of last factory calibration: September 29, 2016
Dates in service: 11/18/2016 - current as of 12/31/2016

Parameter: Temperature and Relative Humidity
Model#: HC2S3
Serial#: 0020002606
Operating Temperature: -40 to +100°C
Temperature Measurement Range: -40 to +60°C
Temperature Accuracy: $\pm 0.1^\circ\text{C}$ (@23°C)
Long-term Temperature Stability: $<0.1^\circ\text{C}/\text{year}$
Relative Humidity Measurement Range: 0-100% non-condensing
RH Accuracy: $\pm 0.8\%$ RH (@23°C)
Long-term RH Stability: $<1\%$ RH/year
Date of last calibration: September 26, 2013
Dates in service: 06/08/2015 - 06/06/2016

Parameter: Temperature and Relative Humidity
Model#: HC2S3
Serial#: 608378861
Operating Temperature: -40 to +100°C
Temperature Measurement Range: -40 to +60°C
Temperature Accuracy: $\pm 0.1^\circ\text{C}$ (@23°C)
Long-term Temperature Stability: $<0.1^\circ\text{C}/\text{year}$
Relative Humidity Measurement Range: 0-100% non-condensing
RH Accuracy: $\pm 0.8\%$ RH (@23°C)
Long-term RH Stability: $<1\%$ RH/year
Date of last calibration: January 26, 2016
Dates in service: 06/06/2016 - current as of 12/31/2016

Parameter: Barometric Pressure
Model#: PTB110
Serial#: K1040006
Operating Temperature: -40 to +60C

Pressure Measurement Range: 600-1060 mb
Humidity: non-condensing
Accuracy: ± 0.3 mb at $+20$ °C
Stability: ± 0.1 mb per year
Date of Last calibration: March 6, 2014
Dates in service: 05/19/2014 - 05/05/2016

Parameter: Barometric Pressure
Model#: PTB110
Serial#: G1760044
Operating Temperature: -40 to $+60$ C
Pressure Measurement Range: 600-1060 mb
Humidity: non-condensing
Accuracy: ± 0.3 mb at $+20$ °C
Stability: ± 0.1 mb per year
Date of Last calibration: March 21, 2016
Dates in service: 05/05/2016 - current as of 12/31/2016

Parameter: Precipitation
Serial#: 59850-514
Model#: TR-525UWS
Units: millimeters (mm)
Sensor type: Tipping Bucket Rain Gauge
Rainfall per tip: 0.01 inch
Operating range: Temperature: 0° to $\pm 50^{\circ}$ C; Humidity: 0 to 100%
Accuracy: $\pm 1.0\%$ up to 2 in/hr
Dates of calibration: July 15, 2015, July 15, 2016

Datalogger:
Model: CR1000
Serial#: 22371
Specs: The CR1000 has a 2MB Flash EEPROM that is used to store the Operating System. Another 128K Flash is used to store configuration settings. A minimum of 2MB SRAM (4MB optional) is available for program storage (16K), operating system use, and data storage. Additional storage is available by using a compact flash card in the optional CFM100 Compact Flash Module. Date of Calibration: 01/07/2015
Dates in service: 01/15/2015 - present
CR1000 firmware/OS version: cr1000.Std.21 (date of last update unknown)
CR1000 Program Versions: TJRTLMEt_6_20150220.CR1

10) Coded variable definitions

Sampling station:	Sampling site code:	Station code:
Tidal Linkage	TL	tjrtlmct

11) QAQC flag definitions

QAQC flags provide documentation of the data and are applied to individual data points by insertion into the parameter's associated flag column (header preceded by an F_). During primary automated QAQC (performed by the CDMO), -5, -4, and -2 flags are applied automatically to indicate data that is above or below sensor range, or missing. All remaining data are then flagged 0, as passing initial QAQC checks. During secondary and tertiary QAQC 1, -3, and 5 flags may be used to note data as suspect, rejected due to QAQC, or corrected.

-5	Outside High Sensor Range
-4	Outside Low Sensor Range

- 3 Data Rejected due to QAQC
- 2 Missing Data
- 1 Optional SWMP supported parameter
- 0 Passed Initial QAQC Checks
- 1 Suspect Data
- 2 Open - reserved for later flag
- 3 Open - reserved for later flag
- 4 Historical Data: Pre-Auto QAQC
- 5 Corrected Data

12) QAQC code definitions

QAQC codes are used in conjunction with QAQC flags to provide further documentation of the data and are also applied by insertion into the associated flag column. There are three (3) different code categories, general, sensor, and comment. General errors document general problems with the CR1000, sensor errors are sensor specific, and comment codes are used to further document conditions or a problem with the data. Only one general or sensor error and one comment code can be applied to a particular data point, but some comment codes (marked with an * below) can be applied to the entire record in the F_Record column.

General Errors

GIM Instrument malfunction
 GIT Instrument recording error, recovered telemetry data
 GMC No instrument deployed due to maintenance/calibration
 GMT Instrument maintenance
 GPD Power down
 GPF Power failure / Low battery
 GPR Program reload
 GQR Data rejected due to QA/QC checks
 GSM See metadata

Sensor Errors

SDG Suspect due to sensor diagnostics
 SIC Incorrect calibration constant, multiplier or offset
 SIW Incorrect wiring
 SMT Sensor maintenance
 SNV Negative value
 SOC Out of calibration
 SQR Data rejected due to QAQC checks
 SSD Sensor drift
 SSN Not a number / unknown value
 SSM Sensor malfunction
 SSR Sensor removed

Comments

CAF Acceptable calibration/accuracy error of sensor
 CCU Cause unknown
 CDF Data appear to fit conditions
 CML Snow melt from previous snowfall event
 CRE* Significant rain event
 CSM* See metadata
 CVT* Possible vandalism/tampering
 CWE* Significant weather event

13) Other remarks / notes

Data are missing due to equipment or associated specific sensors not being deployed, equipment failure, time of maintenance or calibration of equipment, or repair/replacement of a sampling station platform. Any NaNs in the dataset stand for "not a number" and are the result of low power, disconnected wires, or out of range readings. If additional information on missing data is needed, contact the Research Coordinator at the reserve submitting the data.

Small negative PAR values are within range of the sensor and are due to normal errors in the sensor and the CR1000 Datalogger. The Maximum signal noise error for the Licor sensor is +/- 2.214 mmol/m² over a 15 minute interval. These values are automatically flagged and coded as <1> (CAF).

Relative Humidity data greater than 100 are within range of the sensor accuracy of +/-3% and are flagged and coded as suspect, <1> (CAF). Values greater than 103 are rejected <-3>.

Data recorded for all parameters (with the exception of cumulative precipitation) at the midnight timestamp (00:00) are the 15 minute averages and totals for the 23:45-23:59 time period of the previous day. Cumulative precipitation data at the midnight timestamp (00:00) are the sum of raw (unrounded) precipitation data from 00:00 to 23:59 of the previous day. Summing each individual 15-minute total precipitation value from the same period will result in small differences from cumulative precipitation due to rounding. It is especially important to note how data at the midnight timestamp are recorded when using January 1st and December 31st data. Note: Cumulative precipitation is no longer available via export from the CDMO. Please contact the Reserve or the CDMO for more information or to obtain these data.

All periods where sensor values deviated noticeably from the rest of the data set, e.g. periods of high or low temperature, low barometric pressure etc., were evaluated against data from nearby weather stations (Ream Field NALF and Imperial Beach pier) and also compared to local daily analog measurements when available. All such periods were found to be comparable with the ancillary data.

The following time stamps recorded a large negative **MinTemp** value and, therefore, the **ATemp** and **RH** values were rejected [SQR] (CSM): **01/11/16 21:00, 01/13/2016 02:00, 03/12/2016 15:00, 03/13/2016 16:00, 03/17/2016 09:30, 04/11/2016 16:15 and 23:45, 4/17/2016 02:00, 04/29/2016 14:45, and 05/07/2016 20:30.**

The calibrated barometric pressure sensor was being installed between 11:09 and 11:25a on 05/05/2016. **BP** was rejected [SMT] (CSM) at **05/05/2016 11:15 - 11:30.**

A calibrated temp/RH sensor was installed at 14:44 6/6/2016. **Temp** and **RH** data for **6/6/2016 14:45** were rejected [SMT] (CSM).

The tipping bucket was tipped during maintenance. **TotPrcp** for **06/15/2016 13:30** and **CumPrcp** for **06/15/2016 13:30 - 06/16/2016 00:00** were rejected [SMT] (CSM).

The tipping bucket rain gauge was calibrated on **7/15/2016** and was installed at **12:55**. The bucket was tipped twice as a test. **TotPrcp** for **07/15/2016 13:00** and **CumPrcp** for **07/15/2016 13:00 - 07/16/2016 00:00** were rejected [SMT] (CSM).

ATemp and **RH** were rejected [SQR] (CSM) due to the QA/QC check, as the **MaxTemp** was relatively high. These two timestamps were during times of maintenance and cleaning: **08/15/2016 11:00 - 11:15.**

ATemp and **RH** were rejected [SMT] (CSM) due to maintenance and cleaning:
10/14/2016 12:15 - 12:45.

An attempt was made to swap the wind set, but technical issues arose and the original wind set was returned to the meteorological station. All **wind** data was rejected [SMT] (CSM) during this maintenance: **10/14/2016 12:15 - 14:00.**

The wind set was swapped between 12:31 and 13:14 on 11/18/2016. The following **wind** data was rejected [SMT] (CSM): **11/18/2016 12:45 - 13:15.**