

Tijuana River (TJR) NERR Meteorological Metadata
January – December 2018
Latest Update: 11/01/2019

I. Data Set & Research Descriptors

1) Principal investigator(s) & contact persons

Jeff Crooks, Research Coordinator	301 Caspian Way Imperial Beach, CA 91932 Phone: (619) 575-3613 Fax: (619) 575-6913 e-mail: jcrooks@tijuanaestuary.org
-----------------------------------	---

Justin McCullough, Research Associate	301 Caspian Way Imperial Beach, CA 91932 Phone: (619) 575-3613 x321 e-mail: jmccullough@trnerr.org
---------------------------------------	---

2) Entry verification

Data are uploaded from the CR1000 data logger to a Personal Computer (IBM compatible). Files are exported from LoggerNet in a comma-delimited format and uploaded to the CDMO where they undergo automated primary QAQC and become part of the CDMO's online provisional database. During primary QAQC, data are flagged if they are missing or out of sensor range. The edited file is then returned to the Reserve where it is opened in Microsoft Excel and processed using the CDMO's NERRQAQC Excel macro. The macro inserts station codes, creates metadata worksheets for flagged data and summary statistics, and graphs the data for review. It allows the user to apply QAQC flags and codes to the data, append files, and export the resulting data file to the CDMO for tertiary QAQC and assimilation into the CDMO's authoritative online database. For more information on QAQC flags and QAQC codes, see Sections 11 and 12. Justin McCullough is responsible for all data management.

3) Research objectives (Campbell Weather Station):

The principal objective is to record long-term and episodic meteorological data for the Tijuana River Estuary in order to observe any environmental changes or trends over time. Data are also used as corollary information in ongoing biological, hydrological and geographical studies being conducted at the reserve.

4) Research Methods

A model CR1000 Campbell Scientific datalogger samples meteorological sensors every 5 seconds. At 15 minute intervals, averages, totals, or instantaneous readings are taken, depending upon sensor type, and written to a storage table on the CR1000. Data are reported in Pacific Standard Time (PST).

Monthly, sensors on the weather station are inspected for damage or debris. If any is found, it is repaired and/or cleaned. Sensors are removed and sent back to Campbell Scientific for calibration at minimum of every one to two years, depending on the sensor. There were no other analyses done on the meteorological data at present.

Campbell Scientific data telemetry equipment was installed at the Tidal Linkage station on 06/12/2006 and transmits data to the NOAA GOES satellite, NESDIS ID #3B01468A. The transmissions are scheduled hourly and contain four (4) data sets reflecting fifteen minute data sampling intervals. Upon receipt by the CDMO, the data undergoes the same automated primary QAQC process detailed in Section 2 above. The "real-time" telemetry data become part of the provisional dataset until undergoing secondary and tertiary QAQC and assimilation into the CDMO's authoritative online database. Provisional and authoritative data are available at <http://cdmo.baruch.sc.edu>.

The 15 minute Data are collected in the following formats for the CR1000:

- Averages from 5-second data:
 - Air Temperature (°C), Relative Humidity (%), Barometric Pressure (mb), Wind Speed (m/s), Wind Direction (degrees), and Battery Voltage (volts)
- Maximum, Minimum, and their times from 5-second data:
 - Maximum and Minimum Air Temperature (°C; these data are available from the Reserve), Maximum Wind Speed (m/s)
- Wind Direction Standard Deviation (degrees) from 5-second data
- Totals:
 - Precipitation (mm), PAR (millimoles/m²), and Cumulative Precipitation (mm; Cumulative precipitation is no longer available via export from the CDMO. Please contact the Reserve or the CDMO for more information or to obtain these data.)

Recommended calibration frequency for the MET station sensors:

- Temperature/Humidity - yearly recalibration
- Rain Gauge - yearly recalibration
- Wind Speed/Direction - every 2 years factory maintenance
- Barometric Pressure - every 2 years recalibration
- Photosynthetically Active Radiation (PAR) - Apogee Quantum Sensor - every 2 years recalibration
- CR1000 - every 5 years (required beginning 2014, one year initial grace period)

5) Site location and character:

The Tijuana River NERR is located on the Southern Pacific Coast, next to the California border with Mexico at a latitude of 32°34'N and longitude of 117°07'W. The area surrounding the 2,531 acre reserve is heavily developed by residential housing, as is the watershed which drains into the estuary. Approximately two-thirds of the watershed resides in Mexico and is subject to periodic raw sewage outflows. The northeastern section is bordered by a military helicopter training base. Vegetation in the area is dominated by common pickleweed (*Salicornia pacifica*) and Pacific cordgrass (*Spartina foliosa*).

Description of the specific sampling station:

The weather station is located approximately 30m west of the TRNERR Visitor Center at a latitude of 32°34'28.5"N and longitude of 117°07'37.3"W. The station is about 800m northeast of the water quality sampling station at Oneonta Slough. The vegetation surrounding the weather station is mainly upland scrub species.

The anemometer, wind direction and PAR sensors are located at the top of a 3.5m aluminum tower. The temperature and humidity sensors are located midway up (~1.75m) and on the west side of the tower. The barometric pressure sensor is mounted in the CR1000 enclosure at a height of 1.5m. The Tipping Bucket rain

gauge (relocated in 2014) is attached to the fence 2.4 meters to the south-southwest of the main tower. It is 2m above the ground to limit interference from the security fence surrounding the weather station. The sensors were wired to the CR1000 following the protocol in the CDMO Manual.

SWMP Station Timeline:

Station Code	SWMP Status	Station Name	Location	Active Dates	Reason Decommissioned	Notes
TL	P	Tidal Linkage	32°34'28.5"N 117°07'37.3"W	01/01/2001 - present	N/A	N/A

6) Data collection Period

Data was collected for all parameters at the station from 01/01/2018 00:00 and continued through the present.

File Start Date and Time	File End Date and Time
12/15/2017 11:30	01/15/2018 10:30
01/15/2018 10:45	02/16/2018 12:00
02/16/2018 12:15	03/20/2018 09:45
03/20/2018 10:00	04/16/2018 11:45
04/16/2018 12:00	05/15/2018 11:30
05/15/2018 11:45	06/15/2018 11:45
06/15/2018 11:45	07/24/2018 09:30
07/24/2018 09:45	08/15/2018 11:15
08/15/2018 11:30	09/12/2018 09:45
09/12/2018 10:00	10/19/2018 11:00
10/19/2018 11:15	11/15/2018 14:30
11/15/2018 14:45	12/14/2018 16:30
12/14/2018 16:45	1/16/2018 10:45

7) Distribution

NOAA retains the right to analyze, synthesize and publish summaries of the NERRS System-wide Monitoring Program data. The NERRS retains the right to be fully credited for having collected and process the data. Following academic courtesy standards, the NERR site where the data were collected should be contacted and fully acknowledged in any subsequent publications in which any part of the data are used. The data set enclosed within this package/transmission is only as good as the quality assurance and quality control procedures outlined by the enclosed metadata reporting statement. The user bears all responsibility for its subsequent use/misuse in any further analyses or comparisons. The Federal government does not assume liability to the Recipient or third persons, nor will the Federal government reimburse or indemnify the Recipient for its liability due to any losses resulting in any way from the use of this data.

Requested citation format:

NOAA National Estuarine Research Reserve System (NERRS). System-wide Monitoring Program. Data accessed from the NOAA NERRS Centralized Data Management Office website: <http://www.nerrsdata.org/>; accessed 12 October 2018.

NERR meteorological data and metadata can be obtained from the Research Coordinator at the individual NERR site (please see Principal Investigators and

Contact Persons), from the Data Manager at the Centralized Data Management Office (please see personnel directory under the general information link on the CDMO home page) and online at the CDMO home page www.nerrsdata.org. Data are available in comma delimited format.

8) Associated researchers and projects

The meteorological station is part of the NERRS System Wide Monitoring Program (SWMP) that also includes data collection for water quality, using YSI data loggers for in situ measurements (temperature, salinity, dissolved oxygen, turbidity, pH and water depth) and grab samples to analyze nutrient contents (orthophosphate, chlorophyll, ammonium, nitrate/nitrite) in the laboratory.

II. Physical Structure Descriptors

9) Sensor specifications

Parameter: Photosynthetically Active Radiation (PAR) Apogee Quantum Sensor
Units: mmoles/m^2 (total flux)

Sensor type: High stability silicon photovoltaic detector (blue enhanced)

Model#: SQ-110

Serial#: 12144

Light spectrum waveband: 410 to 655 nm

Temperature dependence: $.06 \pm .06\%$ per $^{\circ}\text{C}$

Stability: $\pm 2\%$ change over 1 yr

Operating Temperature: -40°C to 70°C ; Humidity: 0 to 100%

Sensitivity: 0.2 mV per $\mu\text{mol m}^{-2} \text{s}^{-1}$

Multiplier: 0.025

Date installed: April 17, 2017

Date of last calibration: February 6, 2017

Dates in service: 04/17/2017 - current as of 12/31/2018

Parameter: Wind speed

Units: meter per second (m/s)

Sensor type: 18 cm diameter 4-blade helicoids propeller molded of polypropylene

Model#: R.M. Young 05106 Wind Monitor - Marine

Serial#: WM 150921

Range: 0-100 m/s (224 mph)

Accuracy: $\pm 1\%$

Date of last factory calibration: September 29, 2016

Dates in service: 11/18/2016 - 12/17/2018

Parameter: Wind direction

Units: degrees

Sensor type: balanced vane, 38 cm turning radius

Model#: R.M. Young 05106 Wind Monitor - Marine

Serial#: WM 150921

Range: 360° mechanical, 355° electrical (5° open)

Accuracy: $\pm 3^{\circ}$

Date of last factory calibration: September 29, 2016

Dates in service: 11/18/2016 - 12/17/2018

Parameter: Wind speed

Units: meter per second (m/s)

Sensor type: 18 cm diameter 4-blade helicoids propeller molded of polypropylene

Model#: R.M. Young 05106 Wind Monitor - Marine

Serial#: WM 149693

Range: 0-100 m/s (224 mph)

Accuracy: $\pm 1\%$
Date of last factory calibration: November 27, 2018
Dates in service: 12/17/2018 - current as of 12/31/2018

Parameter: Wind direction
Units: degrees
Sensor type: balanced vane, 38 cm turning radius
Model#: R.M. Young 05106 Wind Monitor - Marine
Serial#: WM 150921
Range: 360° mechanical, 355° electrical (5° open)
Accuracy: $\pm 3^\circ$
Date of last factory calibration: November 27, 2018
Dates in service: 12/17/2018 - current as of 12/31/2018

Parameter: Temperature and Relative Humidity
Model#: HC2S3
Serial#: 0020072485
Operating Temperature: -40 to +100°C
Temperature Measurement Range: -40 to +60°C
Temperature Accuracy: $\pm 0.1^\circ\text{C}$ (@23°C)
Long-term Temperature Stability: $<0.1^\circ\text{C}/\text{year}$
Relative Humidity Measurement Range: 0-100% non-condensing
RH Accuracy: $\pm 0.8\%$ RH (@23°C)
Long-term RH Stability: $<1\%$ RH/year
Date of last calibration: November 25, 2015
Dates in service: 05/15/2017 - 05/15/2018

Parameter: Temperature and Relative Humidity
Model#: HC2S3
Serial#: 0020002606
Operating Temperature: -40 to +100°C
Temperature Measurement Range: -40 to +60°C
Temperature Accuracy: $\pm 0.1^\circ\text{C}$ (@23°C)
Long-term Temperature Stability: $<0.1^\circ\text{C}/\text{year}$
Relative Humidity Measurement Range: 0-100% non-condensing
RH Accuracy: $\pm 0.8\%$ RH (@23°C)
Long-term RH Stability: $<1\%$ RH/year
Date of last calibration: January 14, 2017
Dates in service: 05/15/2018 - current as of 12/31/2018

Parameter: Barometric Pressure
Model#: PTB110
Serial#: G1760044
Operating Temperature: -40 to +60C
Pressure Measurement Range: 600-1060 mb
Humidity: non-condensing
Accuracy: ± 0.3 mb at +20 °C
Stability: ± 0.1 mb per year
Date of Last calibration: March 21, 2016
Dates in service: 05/05/2016 - 05/15/2018

Parameter: Barometric Pressure
Model#: PTB110
Serial#: L3220432
Operating Temperature: -40 to +60C
Pressure Measurement Range: 600-1060 mb
Humidity: non-condensing

Accuracy: ± 0.3 mb at $+20$ °C
Stability: ± 0.1 mb per year
Date of Last calibration: March 21, 2016
Dates in service: 05/15/2018 - current as of 12/31/2018

Parameter: Precipitation
Serial#: 59850-514
Model#: TR-525UWS
Units: millimeters (mm)
Sensor type: Tipping Bucket Rain Gauge
Rainfall per tip: 0.01 inch
Operating range: Temperature: 0° to $\pm 50^{\circ}\text{C}$; Humidity: 0 to 100%
Accuracy: $\pm 1.0\%$ up to 2 in/hr
Dates of calibration: July 15, 2015; July 15, 2016; July 26, 2017; July 16, 2018
Dates in service: 07/24/2015 - current as of 12/31/2018

Datalogger:
Model: CR1000
Serial#: 22371
Specs: The CR1000 has a 2MB Flash EEPROM that is used to store the Operating System. Another 128K Flash is used to store configuration settings. A minimum of 2MB SRAM (4MB optional) is available for program storage (16K), operating system use, and data storage. Additional storage is available by using a compact flash card in the optional CFM100 Compact Flash Module.
Date of Calibration: 01/07/2015
Dates in service: 01/15/2015 - current as of 12/31/2018
CR1000 firmware/OS version: cr1000.Std.21(last updated at calibration 01/07/2015)
CR1000 Program Versions: tjrtlmet_6.2_022015

10) Coded variable definitions

Sampling station:	Sampling site code:	Station code:
Tidal Linkage	TL	tjrtlmet

11) QAQC flag definitions

QAQC flags provide documentation of the data and are applied to individual data points by insertion into the parameter's associated flag column (header preceded by an F_). During primary automated QAQC (performed by the CDMO), -5, -4, and -2 flags are applied automatically to indicate data that is above or below sensor range, or missing. All remaining data are then flagged 0, as passing initial QAQC checks. During secondary and tertiary QAQC 1, -3, and 5 flags may be used to note data as suspect, rejected due to QAQC, or corrected.

- 5 Outside High Sensor Range
- 4 Outside Low Sensor Range
- 3 Data Rejected due to QAQC
- 2 Missing Data
- 1 Optional SWMP supported parameter
- 0 Passed Initial QAQC Checks
- 1 Suspect Data
- 2 Open - reserved for later flag
- 3 Open - reserved for later flag
- 4 Historical Data: Pre-Auto QAQC
- 5 Corrected Data

12) QAQC code definitions

QAQC codes are used in conjunction with QAQC flags to provide further documentation of the data and are also applied by insertion into the associated flag column. There are three (3) different code categories, general, sensor, and comment. General errors document general problems with the CR1000, sensor errors are sensor specific, and comment codes are used to further document conditions or a problem with the data. Only one general or sensor error and one comment code can be applied to a particular data point, but some comment codes (marked with an * below) can be applied to the entire record in the F_Record column.

General Errors

GIM	Instrument malfunction
GIT	Instrument recording error, recovered telemetry data
GMC	No instrument deployed due to maintenance/calibration
GMT	Instrument maintenance
GPD	Power down
GPF	Power failure / Low battery
GPR	Program reload
GQR	Data rejected due to QA/QC checks
GSM	See metadata

Sensor Errors

SDG	Suspect due to sensor diagnostics
SIC	Incorrect calibration constant, multiplier or offset
SIW	Incorrect wiring
SMT	Sensor maintenance
SNV	Negative value
SOC	Out of calibration
SQR	Data rejected due to QAQC checks
SSD	Sensor drift
SSN	Not a number / unknown value
SSM	Sensor malfunction
SSR	Sensor removed

Comments

CAF	Acceptable calibration/accuracy error of sensor
CCU	Cause unknown
CDF	Data appear to fit conditions
CML	Snow melt from previous snowfall event
CRE*	Significant rain event
CSM*	See metadata
CVT*	Possible vandalism/tampering
CWE*	Significant weather event

13) Other remarks / notes

Data are missing due to equipment or associated specific sensors not being deployed, equipment failure, time of maintenance or calibration of equipment, or repair/replacement of a sampling station platform. Any NaNs in the dataset stand for "not a number" and are the result of low power, disconnected wires, or out of range readings. If additional information on missing data is needed, contact the Research Coordinator at the reserve submitting the data.

Small negative PAR values are within range of the LI-COR sensor and are due to normal errors in the sensor and the CR1000 Datalogger. The Maximum signal noise

error for the LI-COR sensor is +/- 2.214 mmoles/m2 over a 15 minute interval. These values are automatically flagged and coded as <1> (CAF). Relative Humidity data greater than 100 are within range of the sensor accuracy of +/-3% and are flagged and coded as suspect, <1> (CAF). Values greater than 103 are rejected <-3>.

Data recorded for all parameters (with the exception of cumulative precipitation) at the midnight timestamp (00:00) are the 15 minute averages and totals for the 23:45-23:59 time period of the previous day. Cumulative precipitation data at the midnight timestamp (00:00) are the sum of raw (unrounded) precipitation data from 00:00 to 23:59 of the previous day. Summing each individual 15-minute total precipitation value from the same period will result in small differences from cumulative precipitation due to rounding. It is especially important to note how data at the midnight timestamp are recorded when using January 1st and December 31st data. Note: Cumulative precipitation is no longer available via export from the CDMO. Please contact the Reserve or the CDMO for more information or to obtain these data.

All periods where sensor values deviated noticeably from the rest of the data set, e.g. periods of high or low temperature, low barometric pressure etc., were evaluated against data from nearby weather stations (Ream Field NALF and Imperial Beach pier) and also compared to local daily analog measurements when available. All such periods were found to be comparable with the ancillary data.

Additional Flagging Notes:

The following time stamps recorded a large negative **MinTemp** value (**mintemps are not in the dataset but are available from the Reserve**) and, therefore, the **ATemp** and **RH** values were rejected <-3> [**SQR**] (**CSM**)]:

01/01/2018 02:00	01/02/2018 14:00	01/05/2018 02:30
01/09/2018 12:00	01/23/2018 05:30	01/27/2018 09:30
01/27/2018 18:00	01/28/2018 09:30	02/01/2018 07:45
02/03/2018 05:45	02/12/2018 20:45	02/28/2018 01:30
03/07/2018 13:45	03/15/2018 20:15	03/17/2018 20:45
03/24/2018 12:30	03/27/2018 22:30	03/29/2018 10:30
03/31/2018 10:15	04/01/2018 22:15	04/04/2018 00:45
04/06/2018 23:15	04/11/2018 14:45	04/16/2018 06:15
04/20/2018 11:00	04/23/2018 10:45	

The temp/RH probe was outside its guard during routine maintenance. **ATemp** and **RH** were rejected [**SMT**] (**CSM**) at the following times:

01/15/2018 10:30	03/20/2018 09:45	07/13/2018 9:15 - 9:30
------------------	------------------	------------------------

The temp/RH and BP probes were removed and replaced with calibrated probes. **ATemp**, **RH** and **BP** were rejected [**SMT**] (**CSM**) at 05/15/2018 11:15.

Precipitation occurred on 01/17/2018 that was not captured by the tipping bucket. The manual rain gauge, less than one meter from the tipping bucket, measured approximately 0.02in (0.508mm) and the nearby Imperial Beach Naval Outlying Landing Field weather station recorded 0.01in (.254mm). Both total and cumulative precipitation are coded with CSM for the entire day.

TotPrcp at 07/16/2018 16:00 and **CumPrcp** from 07/16/2018 16:00 through 07/17/2018 00:00 were rejected <-3> [**SMT**] (**CSM**). The tipping bucket was removed for

calibration and upon reinstallation was tipped as a test to ensure it was functioning properly.

The wind set was completely wiped down and cleaned. **WSpd**, **Wdir**, **SDWDir**, and **MaxWSpd** were all rejected **[SMT] (CSM)** at **02/15/2018 12:00**, **07/13/2018 9:00**, and **09/12/2018 9:45**.

An attempt to install a newly inspected, refurbished and compliance tested wind sensor at **12/14/2018 14:15 - 16:30** failed due to technical issues. A second, successful attempt occurred at **12/17/2018 14:30 - 15:00**. All wind parameters were rejected **<-3> [SMT] (CSM)** for both of these time periods.